

Using Synchrophasor Technology to Identify Control System Malfunctions and Monitor Oscillations - Analysis of Select Past WECC System Oscillation Events

**Jim McIntosh, CAISO
and
John Ballance/Bharat Bhargava,
Electric Power Group**

**North American Synchro Phasor Initiative
Meeting**

June 5-6, 2012, Denver, CO

SynchroPhasor Technology for Monitoring Power System Oscillations and Control System Performance

- Control system malfunctions or highly stressed system conditions can result in low damped or growing system oscillations
- These conditions can be monitored and detected by SynchroPhasor Technology in real-time, and later analysis of the data to identify and correct root causes
- The Phasor Grid Dynamics Analyzer (PGDA) was used for detailed off-line analysis of the events using archived data
- In real-time, this can be monitored using Real Time Dynamics Monitoring System (RTDMS®), which is in use at CAISO
- For mode meter analysis, Prof. Trudnowski's code has been incorporated in PGDA and RTDMS (Note – code is being updated)
- Four examples of WECC events that exhibited unusual oscillations caused by control systems of high stress are presented. Operators would have seen these events using real-time tools such as RTDMS. Here PGDA has been used for their analysis. The four events being presented are:
 - October 9, 2003 (caused by Colstrip lines/machines)
 - November 30, 2005 (caused by the governor at Nova Jaffre, Alberta)
 - January 26, 2008 (caused by DC controls)
 - August 4, 2000 (caused by high system stress)


*Electric Power Group, upon GRID-3P platform, U.S. Patent 7,233,843, and U.S. Patent 8,060259. All rights reserved..

Colstrip Units Oscillations Caused by Generator Unit Controls on October 9, 2003 at 13:25 PDT


Event description:

- Oscillations were triggered by the malfunction of control system at Colstrip Power plant
- Oscillations occurred at 0.6 Hz (local mode) and were observed at Colstrip
- Oscillations (approximately +/- 0.05 Hz) clearly observable in frequency at Colstrip
- Damping during the incident was reduced to less than 2 percent
- Power swings of 50+ MW occurred on each generator
- Power swings observed on California-Oregon border (COI lines)
- Oscillations damped when corrective action taken by power plant operator


Large Sustained Frequency Oscillations at Colstrip



Power Flow Oscillations on Colstrip Generators



Modal Analysis of Colstrip Oscillations




Oscillations Caused by Malfunction of Governor Control on a 20 MW Generator in Alberta on November 29, 2005


Event description:

- Oscillations believed to be caused by malfunction of the governor on a 20 MW generator (Nova Jaffre) in Alberta, Canada
- Oscillations caused by the generating unit at 0.28 Hz North-South mode
- Large power oscillations (approximately 70 MW on each Malin-Round Mountain line) observed on California-Oregon lines
- Damping reduced to 1-2 percent
- Oscillations were detected and finally stopped when the units were taken off-line
- This is a classical example of tail wagging the dog
 - excitation at a resonant mode


Power Flow Oscillations on Malin-Round Mountain (COI) Lines



Modal Analysis (Mode Meter) of Power Flows on Malin-Round Mountain Lines



Spectral Analysis of November 29, 2005 WECC Event




Oscillations Caused by PDCI Controls on January 26, 2008


Event description:

- Oscillations caused by the DC system control at Celilo substation when the three 525/230 kV transformers at Big Eddy – near Celilo tripped
- High frequency oscillations occurred at HVDC 230 kV busses at Celilo and Sylmar – the two ends of the PDCI line
- Oscillation frequency varied between 3.6 to 4.4 Hz.
- Damping dropped to 1-2 percent
- Oscillations were confirmed via analog frequency chart and stopped at 15.05 PM when the DC line was removed from service


Large Sustained Frequency Oscillations Occurring at Celilo and Sylmar



Large Sustained Frequency Oscillations Occurring in the System



Spectral Analysis of January 26, 2008 Event



WECC Event on August 4, 2000


at 12:55 PDT

Event description:


- Event was triggered by the loss of BC Hydro-Alberta 500 kV line
- The line was exporting approximately 450 MW to Alberta
- System was operating at high stress level 90+ angle between Grand Coulee(BPA) and Devers(SCE)
- Loss of this line resulted in additional stress on the North-South system, which was already operating at a high stress level
- Increased flow resulted in North-South system oscillations at approx. 0.28 Hz (North-South Inter-area mode) at low damping
- Oscillations continued for over 60 seconds (less than 3 percent damping)
- Peak to peak oscillations of approximately 300 MW observed on the California-Oregon border
- Oscillations damped when a shunt capacitor closed and provided voltage support in Pearl/Keeler station




Large Sustained Frequency Oscillations Occurring in the WECC System on August 4, 2000




Voltage Angle Plot for August 4, 2000 WECC Event



Power Flow Oscillations on California – Oregon Border



Modal Analysis of August 4, 2000 Event



Conclusions / Summary

- **Control system malfunctions and high system stress conditions can cause low damped or un-damped system oscillations**
- **It is important to monitor the critical modes of oscillations and their damping to ensure the system is operating reliably**
- **The following low damped oscillations caused by controls or high system stresses were observed and have been presented:**
 - Colstrip (0.6 to 0.7 Hz) - October 9, 2003
 - Alberta generator (0.28-0.29 HZ) – November 29, 2005
 - DC Control (3.6 Hz to 4.5 Hz) – January 26, 2008
 - North – South (0.28 Hz) August 4, 2000
- **The abnormal system oscillations were detected using SynchroPhasor system data at appropriate locations**
- **Real-time monitoring with RTDMS and off-line analysis with PGDA can be used to identify root causes of oscillations and events and help operators take corrective action**

Thank You.

Any questions ?

Jim McIntosh
California ISO
JMclntosh@caiso.com

John Ballance Bharat Bhargava
Electric Power Group
bhargava@electricpowergroup.com
ballance@electricpowergroup.com