

NIST Interoperability Standards Update

Vahid Madani – PG&E (PSTT)
Damir Novosel – Quanta Tech. (PSTT)
Ron Farquharson – EnerNex Corp.
Ken Martin – IEEE C 37-118

NIST Three Phase Plan

PHASE 1

Identify an initial set of existing consensus standards and develop a roadmap to fill gaps

PHASE 2

Establish public/private Interoperability Panel to provide ongoing recommendations for new/revised standards

NIST Domain Expert Working Groups

T&D, Home-to-Grid, Building-to-Grid,
Industry-to-Grid, PEV-to-Grid,
Business and Policy, Cyber Security

PHASE 3

Testing and Certification Framework

2009

2010

March

September

NIST Phasor related tasks identified in this phase

- Priority Action Plan (PAP) number 13 – Time Synch
- PAP 15 – Cyber Security (somewhat)
- Harmonization of IEC 61850 and IEEE C37.118
- Participate in the SGIP

Domain Expert Working Groups



| | | | | | | | | |
|----|--|---|---|---|---|---|---|---|
| 1 | AMI-SEC System Security Requirements | ✓ | ✓ | ✓ | | | ✓ | ✓ |
| 2 | ANSI C12.19 End Device (Meter) Tables | | ✓ | ✓ | | | | ✓ |
| 3 | BACnet Building Automation & Control Net | | | ✓ | ✓ | | | ✓ |
| 4 | DNP3 – Distributed Network Protocol | | ✓ | | ✓ | ✓ | ✓ | |
| 5 | IEC 60870-6 – Inter-Control Center | | ✓ | | | | | |
| 6 | IEC 61850 – Comms Nets in Substations | | ✓ | | ✓ | ✓ | ✓ | |
| 7 | IEC 61968/61970 – Common Info Model | | ✓ | ✓ | | | | |
| 8 | IEC 62351 – Data Comms Security | | ✓ | | ✓ | ✓ | ✓ | |
| 9 | IEEE C37.118 - Synchrophasors | | ✓ | | | ✓ | | |
| 10 | IEEE 1547 – Distributed Resources | | ✓ | | ✓ | ✓ | ✓ | |
| 11 | IEEE 1686 – IED Cyber Security | | | | ✓ | ✓ | ✓ | |
| 12 | NERC Critical Infrastructure Protection | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |
| 13 | NIST SP 800-53/82 Fed Info Sys Security | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |
| 14 | Open Automated Demand Response | ✓ | ✓ | ✓ | | | | ✓ |
| 15 | Open Home Area Network Requirements | | | | | | | ✓ |
| 16 | ZigBee/HomePlug Smart Energy Profile | | | | | | | ✓ |

- Data from phasor measurement units

- IEEE C37.118 for PMU
- IEC 61850 seen as key standard for field equipment in the future
- Scope of IEC 61850 expanded for wide area communication; e.g. between substations
- Stream based communication or report based communication?
- Rate of publishing

- Several applications requiring accurate time synchronization

- PMUs
 - Sampled values for
 - IEEE 1588, provide
 - Other methods for s
- Time synchronization over comm. networks
- REG-B?

**IEC 61850 / IEEE C37.118 /
Time synchronization**

- Objectives

- Integrate IEEE C37.118 and IEC 61850; define PMU models in IEC 61850 based on IEEE C37.118
- Develop requirements from Smart Grid application, on time synchronization, and time management
- Discuss migration paths

- Multiple applications support
- System reliability
 - Continued operation under single component failure
- Quality of Service guarantee
- Security control – standard compliance
 - Confidentiality
 - Integrity
 - Authentication
 - Logging and audit
- Accommodate future needs
- Balance near term and long term needs

Not readily integrated with substation engineering, automation, and protection

- Automation - C37.118 doesn't reuse IEC 61850 data semantics or wire protocol.
- Existing substation automation equipment cannot receive C37.118.
 - C37.118 only supports data streaming and not report by exception.
 - **Substantial increases in the cost of using PMU data in substations**
- Protection – C37.118 only specifies the use of TCP or UDP.
 - Without access to lower layers of the communication protocol stack, difficult to reserve WAN/VLAN/LAN bandwidth
 - Cannot set the data delivery priority
 - **Phasor data transmitted using C37.118 cannot be used for reliable system protection.**
- Engineering – No standard way to describe a PMU in IEC 61850 Substation Configuration Language (SCL).
 - **No way to configure a system off line.**

- Types of data – NASPINet needs to support exchange of other data including but limited to:
 - Historical phasor data
 - COMTRADE files
 - Alarm/events data
 - Network model configuration data
- Miscellaneous protocol issues
 - There are numerous error handling issues that need to be resolved. Consequently, C37.118 is not a highly reliable protocol
 - Quality and Timestamp loose meaning when C37.118 streams are aggregated and then split up

- No means of guaranteed delivery
- Security – C37.118 does not have security built in
 - RBAC required down to the Item level is needed
- Filtering – one cannot receive only selected items of interest using C37.118
 - Topic based subscriptions are needed
 - Should be able to filter on location of the PMU data
- No context to data – Phasor data without the context of network/device data has limited value
 - NASPINet should be integrated using a common network/device model such as IEC 61850 and/or IEC 61970 Common Information Model (CIM)

IEC/IEEE Joint Standard for Synchrophasors

- Joint development of the entire standard, not just harmonization with IEC 61850.
- Any parts of the synchrophasor standard that need to go into IEC 61850 will be part of that standard, not a separate standard.
- IEEE C37.118 could be split into measurement and communication standards which could simplify the joint IEC work.
- The IEEE C37.118 communication method is widely used for Phasors at this time.
- Transition time would be needed once / if transition from C37.118 to 61850 is to occur

Coordination with IEEE, IEC, and NIST on standard PMU developments

Further formalize the process by expanding existing PSTT documents to become IEEE standards:

- PMU System Testing and Calibration Guide
- Guidelines for synchronization techniques - Accuracy and Availability
- PMU Installation/Commissioning/Maintenance Guide
- SynchroPhasor Accuracy Characterization
- Standard PMU Definition / Basic Specification

Clarify role of PSTT in relationship to focused NIST activities on interoperability standards.

Questions?

