

NASPI Phasor Network Performance

Observations & Recommendations

Terry Bilke
Midwest ISO

October 6, 2010

NASPI Phasor Network Performance Issues

PMU Issues

- **PMUs not reporting** (extended outages)
- **Phasor data gaps** (PMU or network issues)
- **Phasor data with glitches and spikes** (noise that creates false alarms and makes signal processing and analysis more difficult)


Concentrator Issues (creates “black holes” in wide area visibility)

Server and Communications Issues (generally a small chronic loss of data)

PMUs Not Reporting (A Single Day)

September 23rd 2010


12 Key PMUs that did not report data this day, 6 from one provider.




Bad: 0% – 50% = 34 PMUs
Fair: 50% – 95% = 54 PMUs
Good: 95% – 99% = 21 PMUs

Data with Frequent Gaps

September 19th 2010 Frequency Data Trend (Sub-Second Resolution)
Start Time: 19-Sep-2010 08:32:34 PDT
End Time: 19-Sep-2010 09:09:32 PDT




Phasor Data with Glitches and Spikes




Spikes in voltage angle on one PMU observed throughout the day

Noise in frequency (40mHz spikes)



Phasor Data with Glitches and Spikes (cont...)


Voltage Angle Data Trend - Ref: Bull Run.VA.500 kV Bus +SV (Sub-Second Resolution)
Start Time: 14-Jul-2010 14:10:00 PDT
End Time: 14-Jul-2010 14:40:00 PDT



Miller-West Vern.VA.Line +SV
Mean: 18.2779 Std. Dev.: 6.7148

After a brief gap in data, the angles started off from 100° and gradually settled off at 20° - *creates false transient alarms*

Most PMUs Very Good, Some Not



Server/Network Opportunity

Recommendations

- Analysis Project to find Common and Special Causes of Data Problems
 - Develop a Knowledge Base on Issues and Fixes
 - Use PMU registry to facilitate analysis and correction
 - PMU and Concentrator Vendor, Communication Path
 - Quality Status Metric
 - Contact for Support
 - Notification/Escalation Tool/Process
 - Share Data Filtering Methods to Improve Real Time Monitoring and Alarming
-