

# NASPI

## Planning Implementation Task Team

Dmitry Kosterev (BPA) and Mahendra Patel (PJM)

October 5, 2010

# Agenda

1. NASPI PITT Workplan
2. Baselining Power System Performance
3. Synchro-phasor Data Validation
4. Ian Dobson's presentation

# 1. Planning Workplan

- Align with the needs of SGIG projects
- Workplan
  1. **Baselining of Power System Performance**
  2. **System Model Validation**
  3. Load Characterization
  4. Data Mining and Event Detection
  5. **Synchro-Phasor Data Validation**
- Presented to NERC PC

## 2. Power System Performance Baseline

- Phase angles across an interconnection
- Frequency response
  - pre-disturbance, dip and settling frequency, time of minimum dip, size of generation event, etc
- Power Oscillations
  - frequency, damping, energy, mode shapes
- Voltage stability and power-angle sensitivities
- ...





# Western Interconnection Baselining

# Phase Angle Baselineing


- No work is currently done for 2010
- Need to define phase angle clusters (look forward to Ian Dobson's talk)
- Need to develop a tool that generates monthly baselineing reports

# Frequency Response Baseline for the Western Interconnection



# Intermountain Power Plant Outage, June 5 2010


## 1,900 MW






# Palo Verde Unit Outage, June 18 2010

## 1,334 MW




# Relestoke Plant Outage, June 23 2010

## 1,470 MW




# Relestoke Plant Outage, June 23 2010

## 1,430 MW



# RAS Event, September 27 2010

## 2,529 MW generation, 1005 load




# Frequency Response Summary

Date	Time	Event Information	Disturbance Size (MW)	Load Loss (MW)	MW/0.1 Hz @ Min. Frequency	MW/0.1 Hz @ 30 seconds	Initial Frequency (Hz)	Minimum Frequency (Hz)	Frequency at 30 seconds (Hz)	WECC Total Generation (MW)
2010-06-05	10:18	Intermountain 2-unit simultaneous outage	1900		<b>872</b>	<b>1357</b>	59.99	59.772	59.85	103,011
2010-06-18	8:07	Palo Verde U1 outage	1334		<b>883</b>	<b>1647</b>	59.997	59.846	59.916	100,989
2010-06-23	12:45	Revelstoke plant outage	1470		<b>942</b>	<b>1652</b>	59.997	59.841	59.908	119,771
2010-06-23	14:13	Revelstoke plant outage	1430		<b>941</b>	<b>1723</b>	60.002	59.85	59.919	122,046
9/27/2010	14:52	AC RAS gen.drop	2529	1005	<b>1240</b>	<b>1931</b>	59.978	59.774	59.847	
		<b>NORM-ON PEAK*</b>			<b>800 to 1,050</b>	<b>1,400 to 2,000</b>				
		<b>NORM OFF-PEAK*</b>			<b>650 to 920</b>	<b>1,200 to 1,500</b>				
		<b>DESIGN</b>	<b>2,800</b>		<b>560</b>	<b>1120</b>	<b>60</b>	<b>59.5</b>	<b>59.75</b>	

\* Consider using total generation rather than time of day as an indicator

# Oscillations Baseline


- Mode Meter estimates damping of inter-area power oscillations from ambient noise data



# Oscillations Baselineing

- Dan Trudnowski did the original oscillation baselineing for 2008 season
  - Reported at NASPI meeting in Vancouver
- A baselineing tool is installed in BPA lab in May 2010
  - Many unusual operating conditions during 2010


# WECC Open Loop Operation – July 29, 2010



24 hours




# Alberta separated – September 2, 2010



3 hours

# Round Mt – Table Mt DLL – September 27, 2010



1 hour

# Oscillations Baselineing – 2010

- Observations
  - Greater variability in oscillation damping and frequency on daily scale compared to 2008
    - Trying to understand the reasons
  - Significantly less consistency in damping estimates (5% to 20% swings over 20 min period)
    - Need to understand the performance issues
- Need to develop a tool that generates monthly baselineing reports
- Take a closer at the unusual operating conditions

# 3. Synchro-Phasor Data Validation

- PMU data can be corrupted, and the data quality flags may not be able to tell you that
- How to make sure that the synchro-phasor data can be trusted for real-time applications – operator alarms or automated controls ?
- The data can look “unusual” because (a) the data is corrupted or (b) the system goes through a disturbance. How can we tell the difference ?

# Ian Dobson