



Applicability of Synchrophasor Data for Fault Analysis

N. Perera
ERLPhase Power Technologies
Winnipeg, MB
Canada


- Introduction
- PMU data for fault analysis
 - Sequence components
 - Impedance based fault location algorithms
- Factor considered
 - Effect of the filter type (P/M)
 - Effect of the fault duration (Number of cycles)
- Conclusions

- The synchrophasor standard C37.118.1a-2014 presents two performance class filters
 - P : ~2 cycle duration filter
 - M: ~5 cycle duration filter
- This presentation focuses on the applicability of the P and M class synchrophasor data for fault analysis purposes.
- The synchrophasor data captured from an industrial PMU implemented as per the latest PMU standard was used for this analysis.
- Data is captured using in-built PDC program available with the device.

PMU Data During Faults : P Class



- 2 cycle faults




PMU Data During Faults : P Class




- 3 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Seconds


145.50 145.60 145.70 145.80 145.90 146.00 146.10 146.20 146.30 146.40

PMU Data During Faults : P Class




- 4 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Seconds


175.10 175.20 175.30 175.40 175.50 175.60 175.70 175.80 175.90 176.00

PMU Data During Faults : P Class




- 5 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:20:59.184028
WPG-Veri



Seconds

198.30 198.40 198.50 198.60 198.70 198.80 198.90

PMU Data During Faults : P Class

- Summary

Duration (cycles)	Zero Seq. Voltage (V)	Zero Seq. Current (A)
2	9.5 V	0.72 A
3	10.1 V	0.83 A
4	10.1 V	0.83 A
5	10.1 V	0.83 A




PMU Data During Faults : M Class




- 2 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Seconds


35.10 35.20 35.30 35.40 35.50 35.60 35.70 35.80

PMU Data During Faults : M Class




- 3 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Seconds


55.80 55.90 56.00 56.10 56.20 56.30 56.40 56.50 56.60

PMU Data During Faults : M Class




- 4 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1:Vseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1:Iseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Seconds


91.20 91.40 91.60 91.80 92.00 92.20 92.40

PMU Data During Faults : M Class




- 5 cycle faults


Bay1.Va
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri




Bay1.Ia
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Vseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri



Bay1.Iseq:ZeroSeq
Verification
2018/Apr/16 19:36:59.684028
WPG-Veri




Seconds

138.70 138.80 138.90 139.00 139.10 139.20 139.30 139.40 139.50 139.60 139.70

PMU Data During Faults : M Class



- 6 cycle faults



PMU Data During Faults : M Class


- Summary

Duration (cycles)	Zero Seq. Voltage (V)	Zero Seq. Current (A)
2	8.2 V	0.71 A
3	10.9 V	0.9 A
4	10.4 V	0.87A
5	10.1 V	0.83 A
6	10.1 V	0.83 A



Impedance Based Fault Location : M Class

- Method: Takagi Algorithm
 - PMU data (120 samples/sec = 2 samples/cycle)
 - M class (C37.118.1a-2014)
- 3 cycle fault
 - Actual: 3 km; Estimated: 6.7 km



- Effect of the fault duration (single phase to ground fault)

Duration (cycles)	Actual Distance (km)	Estimated Distance (km)
3	3.0 km	6.7 km
4	3.0 km	3.8 km
5	3.0 km	3.9 km
6	3.0 km	4.0 km



- Use of synchrophasor data for fault analysis purposes was investigated for both P and M filters (C37.118.1a -2014)
 - Sequence components for fault level detection
 - Impedance based fault location estimation
- Summary for P Class filters
 - 2 cycle data provides less than 5% error
 - 3 cycle data provides less than 1% error
- Summary for M Class filters
 - 4 cycle data provides less than 5% error
 - 5 cycle data provides less than 1% error



**Thank you !
Questions ?**