



Electric Power Group

Applicability of Synchrophasor Data for Fault Analysis

NASPI, April 2018

Nuwan Perera, Ph.D., P.Eng.
ERLPhase Power Technologies, Winnipeg, MB
Canada

Krish Narendra, Ph.D.
Electric Power Group, LLC, Pasadena, CA
USA

- Introduction
- PMU data for fault analysis
 - Phasors and sequence components
 - Impedance based fault location estimations
- Factors considered
 - Filter type (P/M)
 - Fault duration
- Analysis of data
 - Faults
 - SSO/SSR
- Conclusions

- The synchrophasor standard IEEE C37.118.1a-2014 presents two performance class filters.
 - P & M
- This presentation focuses on the applicability of the P and M class synchrophasor data for fault analysis.
- The synchrophasor data captured from an industrial PMU implemented as per IEEE C37.118.1a- 2014 was used for this analysis.
 - Simulated data from a Real Time Digital Simulator (RTDS)
 - Field reported events
- Data is captured using the in-built PDC program available with the device.


Important Considerations

- Typical fault durations
 - Depends on the response of the protection and speed of the circuit breakers.
 - Response of the conventional relays: **~1 cycle**, high speed CBs : **~1 cycle**
 - **~2 cycle**
- Effect of the filters (P/M)
 - Finite Impulse Response with ~2 cycles (P) and ~ 5 cycle (M)
- Reporting rates available


System frequency	50 Hz			60 Hz					
Reporting rates (F_s —frames per second)	10	25	50	10	12	15	20	30	60

- Testing Considerations/ Parameters
 - Testing was done with the faults simulated at 2 cycles and above
 - Selected reporting rate = 60 Hz (60 Hz system)

- RTDS Testing: Simulated Waveforms



- DOBLE Amplifier: Real time playback of recorded waveforms



PMU Settings



- Basic PMU Settings

PMU Definition

Sample Rate: 60 frames / second PMU Standard: C37.118.1-2011 (M class)

Header Frame Text: Test

Reporting Format

Phasor: Integer

Analog: Integer

Freq / ROC Freq: Integer

	Selected Channel	Full Scale	Unit	Active	Name to Report
PMU Phasors					
Row 1	Bay1:Va	276	kV	<input checked="" type="checkbox"/>	Bay1:Va
Row 2	Bay1:Vb	276	kV	<input checked="" type="checkbox"/>	Bay1:Vb
Row 3	Bay1:Vc	276	kV	<input checked="" type="checkbox"/>	Bay1:Vc
Row 4	Bay1:Ia	250	kA	<input checked="" type="checkbox"/>	Bay1:Ia
Row 5	Bay1:Ib	250	kA	<input checked="" type="checkbox"/>	Bay1:Ib
Row 6	Bay1:Ic	250	kA	<input checked="" type="checkbox"/>	Bay1:Ic

Phasor Options
 Analog Options
 Digital Options

- Angle Reference – PMU Settings

Angle Reference for this Channel Group provided by

- Angle Calibration
 - RTDS and PMU – Connected to GPS – 1 PPS

TESLA Analog Input Configuration

Element:	Type	Description	Channel	Module Type	
Bay 1	<input type="text" value="Va"/>	<input type="text"/>	<input type="text" value="9"/>	<input type="text" value="401006 69Vac Isolated Neutral"/>	
Units	2 kV/V	Angle Offset	Rate of Change Interval	Single Harmonic Number	Nominal Level
kV	<input type="text" value="View/Set Scale"/>	<input type="text" value="0.34"/>	<input type="text" value="1.0"/> Cycle(s)	<input type="text" value="3"/>	<input type="text" value="69"/> V
Actions:					




- Test Cases
 - Effect of fault during - P class estimation
 - Effect of fault during - M class estimation
 - Fault location calculation – M class

PMU Data During Faults : P Class




- 2 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : P Class




- 3 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : P Class




- 4 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : P Class




- 5 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : P Class

- Summary: PMU reporting at 60Hz




Duration (cycles)	Zero Seq. Voltage (V)	Zero Seq. Current (A)
2	9.5 V	0.72 A
3	10.1 V	0.83 A
4	10.1 V	0.83 A
5	10.1 V	0.83 A

PMU Data During Faults : M Class




- 2 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : M Class




- 3 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : M Class




- 4 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : M Class




- 5 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : M Class



- 6 cycle faults: PMU reporting at 60Hz



PMU Data During Faults : M Class

- Summary: PMU reporting at 60Hz


Duration (cycles)	Zero Seq. Voltage (V)	Zero Seq. Current (A)
2	8.2 V	0.71 A
3	10.9 V	0.9 A
4	10.4 V	0.87A
5	10.1 V	0.83 A
6	10.1 V	0.83 A

Over-shoot



Impedance Based Fault Location : M Class

- Method: Takagi Algorithm
 - PMU data (120 samples/sec = 2 samples/cycle)
 - M class (C37.118.1a-2014)
- 3 cycle fault
 - Actual: 3 km; Estimated: 6.7 km



- Effect of the fault duration (single phase to ground fault)


Duration (cycles)	Actual Distance (km)	Estimated Distance (km)
3	4.0 km	6.7 km
4	4.0 km	3.8 km
5	4.0 km	3.9 km
6	4.0 km	4.0 km



- Test Cases
 - 3-cycle fault leading to SSO/SSCI condition
 - Application: a windfarm connected to a series compensated line
 - SSO/SSCI
 - Application: a windfarm connected to a series compensated line

3- cycle fault leading to a SSO/SSCI

- High Speed Record




3- cycle fault leading to a SSO/SSCI

- Sub-harmonics



Sub-Harmonic Magnitude (RMS)




	Current 1 A	Current 1 B	Current 1 C
Fundamental (A-RMS)	0.753	0.706	0.723
TSHD (%)	244.555	264.247	279.293
Dominant SH Frequency (Hz)	24.139	24.195	24.073
Dominant SH Magnitude (A-RMS)	1.813	1.858	2.013

3- cycle fault leading to a SSO/SSCI

- PMU Calculations: P- Class, 60 samples/sec : Magnitudes


3rd reporting followed by the fault



3- cycle fault leading to a SSO/SSCI


- PMU Calculations: P- Class, 60 samples/sec: Angles

3rd reporting followed by the fault



3- cycle fault leading to a SSO


- PMU Calculations: M- Class, 60 samples/sec: Magnitudes
3rd reporting followed by the fault




3- cycle fault leading to a SSO

- PMU Calculations: M- Class, 60 samples/sec: Magnitudes


3rd reporting followed by the fault



- Sub-harmonics



Sub-Harmonic Magnitude (RMS)




	TRW.Ia.TRW A PH.	TRW.Ib.TRW B PH.	TRW.Ic.TRW C PH.
Fundamental (A-RMS)	0.646	0.636	0.635
TSHD (%)	159.726	146.783	156.706
Dominant SH Frequency (Hz)	11.204	11.351	11.327
Dominant SH Magnitude (A-RMS)	1.028	0.960	1.012

SSO/SSCI Event – PMU Reporting



- PMU Calculations: 60 samples/sec: Magnitudes



- Use of synchrophasor data for fault analysis purposes was investigated for P and M filter applications(C37.118.1a -2014).
 - Phasor data, Sequence components and impedance
- Analysis was carried out using simulated and actual fault data.
 - P class filters require ~2+ cycle data to provide an acceptable accuracy
 - M class filters require ~5 cycle data to provide an acceptable accuracy
- Impact of the sub-harmonics on the synchrophasor data was analyzed using field reported SSO/SSR events.
 - P class filter outputs showed higher impact compared to M class filter outputs.
- Further testing is being carried out with more recorded/simulated events to make this analysis comprehensive
 - Report for PRSV Task Team



**Thank you !
Questions ?**