

**NASPI Work Group Meeting
Control Room Solutions Task Team (CRSTT)
Breakout Session Report**

**Presenters: Mike Cassiadoro & Jim Kleitsch
October 30, 2019**



CRSTT, DisTT & PRSVTT Joint Agenda

- I. Introductions
- II. Review mission, goals and objectives for each Task Team**
- III. CRSTT: Work Products Review**
- IV. PRSVTT: Revised PMU Standard
- V. DisTT: European Distribution Operators' Perspective
- VI. Distribution PMU Use Case Survey
- VII. Train the Trainer Recap/Summary**
- VIII. Discussion: Synchrophasors for wildfire mitigation
- IX. Operations Use Case Effort**
- X. Discuss distribution-specific use cases (DisTT and PRSVTT)
- XI. Next Steps & Round Table

CRSTT Mission

CRSTT will work collectively with other NASPI task teams to advance the use of real-time synchrophasor apps for the purpose of improving control room operations and grid reliability.

CRSTT will utilize its experience and regional diversity to provide advice, direction, support and guidance to NASPI stakeholders and other organizations involved in the development and implementation of real-time synchrophasor apps.

CRSTT Goals


1. Develop a series of use case summary docs that define how entities are using synchrophasor data to provide operational value.
2. Create additional video event files for use cases and simulated events.
3. Gather operator feedback on synchrophasor-based apps.
4. Support the design, development and delivery of synchrophasor-related training for ops staff.
5. Develop a series of Lessons Learned docs related to the use of synchrophasor technology in the operations environment.
6. Draft new and update existing focus area documents as the need arises.

Focus Area Documents

1. [System Islanding Detection and Blackstart Restoration](#) – June 2015.
 - (Kleitsch – ATC, Cassiadoro – TRS)
2. [Using Synchrophasor Data for Voltage Stability Assessment](#) – Nov. 2015.
 - (Farantatos – EPRI, Vaiman – V&R Energy)
3. [Using Synchrophasor Data for Phase Angle Monitoring](#) – May 2016.
 - (Cassiadoro – TRS, Nuthalapati – LCRA)
 - **Requests for updates sent on 8/20/2019 with response date of 9/27/2019.**
4. **Enhanced State Estimation Survey –Preliminary responses received; more analysis needed.**
 - (Vaiman – V&R Energy, Kleitsch – ATC)
5. [Using Synchrophasor Data for Oscillation Detection](#) – Feb. 2018.
 - (Nuthalapati –LCRA, Dyer –EPG, Blevins and Rjagopalan –ERCOT, Patel -EPRI)
6. [Using Synchrophasor Data to Determine Disturbance Location](#) – Feb. 2019.
(Nuthalapati – LCRA, Zweigle –SEL Inc., Cassiadoro –TRS)
7. **Using Synchrophasor Data to Monitor Reactive Power Balancing – FUTURE**
 - (Cassiadoro -TRS, Peak –Zhang, Vaiman –V&R Energy)

Video Event Files

Objective – Continue building library of events to demonstrate value PMU data provides when analyzing abnormal events and disturbances.



Video
PMU versus SCADA Video Events Summary . Please refer to EPG's template and the Synchrophasor Data File Format .CSV when creating a video event.
Video 1 - Current and voltage oscillations observed on the 138 kV system during testing of new generator controls (65 MW gas turbine). RTDMS PMU vs. SCADA Video 1
Video 2 - Voltage oscillations observed on the 230 kV system when a water pump was taken offline. RTDMS PMU vs. SCADA Video 2
Video 3 - Voltage oscillations observed following the loss of a 345 kV line during a period of high wind generation. RTDMS PMU vs. SCADA Video 3
Video 4 - Real and Reactive Power oscillations observed on the 69 kV system during a period of high wind generation with the plant radially connected (i.e. one of two normal source lines out of service). RTDMS PMU vs. SCADA Video 4
Video 5 - Real and Reactive Power oscillations observed during a period of high wind generation. RTDMS PMU vs. SCADA Video 5
Video 6 - Real Power and voltage oscillations observed following the loss of a large generator. RTDMS PMU vs. SCADA Video 6
Video 7 - Wind farm Oscillation Detection and Mitigation using Synchrophasor Technology Wind Farm Oscillation Detection and Mitigation
Video 8 - A 230kV fault followed by a loss of a large generation plant caused system frequency to drop approximately 72mHz momentarily, while having an impact on nearby system voltages and online generators (Clip 1 , Clip 2 , Clip 3)
Video 9 - Please be patient with the download, the video is very large. This video captures the actual synchronization of a large generator to the electric grid. The windows in the visualization tool capture frequency, output power, voltage angle, and voltage magnitude of the generator and at a reference point on the electric grid.

Use Case Documents

Objective – Develop docs that demonstrate ways that grid operators and electric utilities are using synchrophasor data to provide operational value.

Event ID	Event	Event Category	Entities Involved	Event Description	Extended Description in Related NASPI Technical Paper	Safety Impact	Reliability Impact	Budgetary Impact
TE02	Failing potential transformer	Transmission Equipment	ATC	Abnormal voltage signature found while reviewing PMU data led to discovery of a failing potential transformer which was subsequently isolated and replaced.	p.38	The utility avoided safety risk to personnel that might have been in close proximity to the PT during its failure.		Utility avoided costs associated with customer minutes of interruption that would have resulted from the potential transformer's failure had the condition not been identified and a mobile transformer placed in service to facilitate the outages necessary for its replacement.
TE03	Loose connections in potential circuits	Transmission Equipment	OG&E	Fluctuations observed in positive sequence voltage data collected from PMUs led to discovery of a loose fuse connection in a CCVT safety switch. PMU data has been used in a similar fashion to reveal faulty terminations, animal-damaged conductor and contact corrosion.	p.40			Utility avoided costs associated with equipment damage and customer minutes of interruption that might have resulted had the issues not been addressed.

NASPI WG Mtg. – Technical Workshop

For its technical workshop, NASPI hosted a “train-the-trainer” session for the *Use of Time-Synchronized Measurements in the Real-Time Operations Horizon* training course.

The workshop was intended for grid operator and electric utility trainers that wish to incorporate the course into their respective training programs, but others are also welcome to attend.

The workshop explained how the course was designed, reviewed course materials and provided pointers on how to customize the training to meet a company’s specific needs.

Operational Use Case Discussion

What do we hope to achieve by developing operational use case documents?

What resources are available to pull information from for developing operational use cases?

How can we engage grid operators, electric utilities, research institutions and vendors to help develop operational use cases?

CRSTT – Primary Contacts

Name: Michael Cassiadoro

Email: mcassiadoro@totalreliabilitysolutions.com

Phone: 360-836-9008

Name: Jim Kleitsch

Email: jkleitsch@atcllc.com

Phone: 608-877-8102

Next NASPI CRSTT Conference Call: Nov. 26, 2019.

Next NASPI WG Meeting: April 2020 in Minneapolis, MN.