

# NERC

NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## NERC White Paper: Recommended Disturbance Monitoring for IBR


Tim Fritch  
SMWG

**RELIABILITY | RESILIENCE | SECURITY**




- Background
- Events
- Challenges
- Recommendations
- Summary

- Paper was developed to support recommendations from Canyon 2 Fire and Blue Cut Fire events (*approved 2020*)
  - Identifies potential data issues
  - Recommended data to be collected from inverter-based resources
  - Existing industry best practices
  - Recommended solutions to address this potential reliability gap.
- Insufficient data available from the generating resources and transmission grid recording devices to identify the specific causes of abnormal behavior from the inverter-based resources
- [https://www.nerc.com/comm/PC/SMSResourcesDocuments/White\\_Paper\\_IBR\\_Disturbance\\_Monitoring.pdf](https://www.nerc.com/comm/PC/SMSResourcesDocuments/White_Paper_IBR_Disturbance_Monitoring.pdf)




- Number of inverters reported tripping on frequency below 57 Hz (Grid Freq only fell to 59.85 Hz)
- Analyzed DFR data for fault event (26 Degree phase jump)



- Data from one of the generator inverter
  - The inverter tripped on transient overvoltage (not detected at the point of interconnection)
  - The inverter also reported a frequency of around 54.5 Hz caused by the distorted waveform during and immediately after the fault event.
- [https://www.nerc.com/pa/rrm/ea/1200 MW Fault Induced Solar Photovoltaic Resource /1200 MW Fault In duced Solar Photovoltaic Resource Interruption Final.pdf](https://www.nerc.com/pa/rrm/ea/1200%20MW%20Fault%20Induced%20Solar%20Photovoltaic%20Resource%20Interruption%20Final.pdf)

- Multiple plants reported inverter tripping
- Transient overvoltage that occurred during the on-fault conditions that resulted in inverter tripping.



- DFR data at the POI showed voltage below nominal at the POI (within the PRC-024-2 voltage protection ride-through curve).
- Without the inverter-level oscillography data to analyze, the POI data with (unsynchronized) SERs of tripping provided little information to deduce exactly why the inverters were tripping.
- <https://www.nerc.com/pa/rrm/ea/October%209%202017%20Canyon%202%20Fire%20Disturbance%20Report/900%20MW%20Solar%20Photovoltaic%20Resource%20Interruption%20Disturbance%20Report.pdf>

- **Lack of Inverter Codes or High Resolution Oscillography Data**
  - Many inverter-based resources were not able to provide any inverter fault codes or high resolution oscillography data for detailed analysis.
  - Local storage in a rolling memory that would often be overwritten by new data in just a couple of days.
  
- **Time Skew in Low-Resolution Telemetered Data**
  - Example: telemetry system is updated on a four second cycle rate.
  - Data not time synchronized to a GPS clock or similar device
  
- **Slow Manual Process**
  - Very challenging and inefficient
  - After the manual review is completed, only a small portion of what actually happened at the resource can be ascertained
  - Measurement requirements are not in the pro forma large or small generator interconnection agreements

- Inaccurate Models for Simulation
  - Most models did not accurately represent momentary cessation, and used some other form of ride-through settings in the model or used generic default parameters
  - Studies performed do not have a complete representation of reality.

- **Modifying NERC Reliability Standard PRC-002**
  - Standard goal - “to have adequate data available to facilitate analysis of BES Disturbances.”
  - Existing standard focuses on synchronous machine theory – high fault current
  - DDR installations at large unit or plants locations – does not account for aggregate ratings of large areas of wind or solar PV
  
- **Recommended Data Collection**
  - Plant Control Settings and Static Values
  - Plant SCADA Data
  - SER Data
  - DFR Data
  - DDR Data
  - Inverter Fault Codes and Dynamic Recordings



- **Inaccurate Models for Positive Sequence Simulation**
  - Parameters of the models for studies do not completely represent large disturbance behavior
  - Most models did not accurately represent momentary cessation – generic parameters
  
- **Time Synchronization**
  - Data needs to be time synchronized to a common time source, both within the plant and with external resources - an accuracy of one millisecond or greater
  
- **Duration of Event Captures**
  - Data should include at least 200 milliseconds prior to the trigger and at least 1 second after the trigger.
  
- **Equipment Selection**
  - Diverse range of equipment installed at inverter-based resources.
  - Plant-level information can be captured by the plant-level controller itself, by digital relays, PMUs, or DFRs installed at the substation, or other types of measurement devices.

- **Modify NERC Reliability Standard PRC-002-2**
  - Currently focuses on short circuit MVA methodology
  - Outdated??
- **Adoption of recommended data collection by Inverter Based Resources**
  - *NERC Reliability Guideline: BPS-Connected Inverter-Based Resource Performance*
- **Modify the pro forma Large and Small Generator Interconnection Agreements**
  - The number of solar PV generating resources continues to grow rapidly as well as the installed capacity of those resources.
  - Majority of these resources are not subject to NERC Reliability Standards since they do not meet the size criteria of a BES resource.



# Questions and Answers